Phone +49 (0) 28 45 / 2 02-0 Fax +49 (0) 2845/202-265

E-Mail trox@trox.de www.trox.de



Declaration of Hygiene Conformity

Active Chilled Beams Type DID300B

Object of the inspection

TROX GmbH, Heinrich-Trox-Platz, D-47504 Neukirchen-Vluyn, Germany, hereby confirm that the active chilled beams of type DID300B meet the hygiene requirements specified by the standards and regulations listed below.

- · European standard
 - EN 13779 (09/2007)
- · German standards
 - VDI 6022, part 1 (07/2011)
 - VDI 3803 (02/2010)
- Austrian standards
 - ÖNORM H 6021 (09/2003)
- Swiss SWKI regulations
 - VA104-01 (04/2006)

For the purpose of this declaration of conformity a sample of each type mentioned above was viewed at the TROX GmbH factory, Heinrich-Trox-Platz, 47504 Neukirchen-Vluyn, Germany, and related data sheets, technical literature, and inspection reports were appraised.

Summary of the test result

The examination of the above-mentioned sample equipment and the appraisal of the available documents have shown that the hygiene requirements specified by the above-mentioned standards and regulations are met.

We hereby confirm that the active chilled beams of type DID300B meet the hygiene requirements of the specified standards and regulations.

Neukirchen-Vluyn, Germany, 08 November 2011

Dipl.-Ing. Dirk Scherder trained according to VDI 6022, category A

Product Management

Dr. Sloedy

Dipl.-Ing. Jan Heymann

Manager Quality Systems

